

Port O'Connor Municipal Utility District
39 Denman Drive
Port O'Connor, Texas 77982

WATER QUALITY '03

PORT O'CONNOR MUNICIPAL UTILITY DISTRICT
Public Water Supply No. 0290065

Excellence in Water Quality

POC Municipal Utility District, 39 Denman Drive, Port O'Connor, Texas 77982 Tel. 361/983-2652

Dear Customer:

The Port O'Connor Municipal Utility District is pleased to provide you with this calendar year 2003 Water Quality Report. We hope you will be pleased to learn about the high quality of drinking water produced and distributed for you by the professional staffs of the District and our drinking water supplier, GBRA.

The federal Safe Drinking Water Act (SDWA) requires water utilities to issue an annual report to customers that explains where your drinking water comes from, what it contains, and the health risks that our water testing and treatment program are designed to prevent.

The Texas Commission on Environmental Quality (TCEQ) inspects the drinking water production and distribution systems on an annual basis, as required by law. **Your drinking water from the GBRA surface water treatment plant near Port Lavaca, Texas meets or exceeds all federal and state established water quality standards.** The tables in this report list all substances that were detected in the treated water during calendar year 2003, and the highest levels at which they were detected. The tables also reflect the highest levels allowed by federal regulatory agencies.

Please read this information carefully and if you have questions, please do not hesitate to call the phone numbers listed in this report.

Customer Views Welcome

The District and GBRA strongly support the national primary drinking water regulations compliance process. Questions about water quality may be answered by the District office in Port O'Connor at 39 Denman Dr., phone 361/983-2652, address Box 375, Port O'Connor, Texas 77982, or the GBRA office phone 361/552-9751, address Box 146, Port Lavaca, Texas 77979. Calls to these offices by customers for further information are most welcome.

The District Directors hold their monthly meeting the second Thursday of each month.

Special Notice for the ELDERLY, INFANTS, CANCER PATIENTS, people with HIV/AIDS OR OTHER IMMUNE PROBLEMS:

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants, can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

The United States Environmental Protection Agency (EPA) and the Center for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the EPA's Safe Drinking Water Hotline (1-800-426-4791).

En Español

Este reporte incluye la informacion importante sobre su agua de beber. Para obtener una copia de esta informacion o traducir en Espanol, favor de llamar 361/983-2652 durante las horas regulares de oficina.

Where Do We Get Our Drinking Water and What Happens to It?

Surface water (water from a lake, pond, river or stream) is diverted from the Guadalupe River and pumped to the GBRA water treatment plant. There, licensed operators treat the water by settling and filtering out suspended solids, dirt, and other organic particles until the water reaches a crystal-clear quality. A disinfectant compound of chlorine and ammonia is used to destroy any pathogens (germs) present. Fluoride is added to promote dental health.

The Port O'Connor Municipal Utility District purchases water from the GBRA plant as a wholesale contract customer. In addition, a groundwater well in Port O'Connor may be used for standby emergency services only. Severn Trent, Inc. is the contract operating company for the District.

Required Additional Health Information

In order to ensure that tap water is safe to drink, the United States Environmental Protection Agency (EPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

All drinking water, **(including bottled water)**, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

(A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;

(B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

(C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, stormwater runoff, and residential uses;

(D) Organic chemical contaminants, including synthetic and volatile organics, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems;

(E) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Many constituents (such as calcium, sodium or iron) which are often found in drinking water, can cause taste, color, and odor problems. The taste, color and odor constituents are called secondary constituents and are regulated by the state of Texas, not EPA. These constituents are not causes for health concerns. Secondary constituents may affect the appearance and taste of your water.

Secondary constituents may affect the appearance and taste of your water.

What We Found

The following table contains all of the chemical constituents that have been found in your drinking water. EPA requires water systems to test for more than 90 constituents. The column marked "Highest Level at Any Sampling Point" shows the highest test results during the year. The "Source of Constituent" column shows where this substance usually originates.

DEFINITIONS:

Maximum Contaminant Level (MCL) - the highest level of a contaminant allowed in drinking water.

MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant allowed in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

NTU = Nephelometric Turbidity Units, a measure of clarity.

ppm = parts per million, or milligrams per liter (mg/L).

ppb = parts per billion, or micrograms per liter (µg/L).

NA = MCL not applicable or not regulated.

TABLE I - Test results for the GBRA water supply to Port O'Connor (Sampled at the GBRA Water Treatment Plant)

Year	Detected Constituent	Highest Level at Any Sampling Point	Number of Analyses	MCL	MCLG	Unit of Measure	Source of Constituent
------	----------------------	-------------------------------------	--------------------	-----	------	-----------------	-----------------------

Inorganics

2002	Barium	0.074	1	2	2	ppm	Discharge of drilling wastes; erosion of natural deposits.
2003	Fluoride	0.99	2	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; runoff from fertilizer use.
2003	Nitrate	0.22	2	10	10	ppm	Runoff from fertilizer use; leaching from septic tanks; treated wastewater effluent; erosion of natural deposits.
2002	Chromium	1.49	1	100	100	ppb	Discharge from steel and pulp mills; erosion of natural deposits.

Organics

Year	Detected Constituent	Concentration Detected	Number of Analyses	MCL	MCLG	Unit of Measure	Source of Constituent
2003	Atrazine	0.33	1	3	3	ppb	Runoff from herbicide used on row crops.

Unregulated Contaminants

Year	Constituent	Average Concentration of Analysis	Range of Detected Levels	Reason for Monitoring
2003	Chloroform	11.2	10.8 - 11.6	Monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.
2003	Bromoform	1.65	1.6 - 1.7	Same as above.
2003	Bromodichloromethane	18.8	18.1 - 19.5	Same as above.
2003	Chlorodibromomethane	14.05	13.7 - 14.4	Same as above.

Turbidity

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches. Turbidity is measured up to 6 times per day.

Year	Detected Constituent	Highest Single Measurement	Lowest Monthly % of Samples Meeting Limits	Turbidity Limits	Unit of Measure	Source of Constituent
2003	Turbidity	0.23	100	0.30	NTU	Organic particles.

2003 Total Coliform NOT DETECTED

Fecal Coliform NOT DETECTED

TABLE II - Test results for the water supply in Port O'Connor (After delivery by GBRA and POC distribution system)

Lead and Copper (None taken for 2003 - analyzed every 9 years)

Year	Detected Constituent	The 90th Percentile	Number of Sites Exceeding Action Level	Action Level	Unit of Measure	Source of Constituent
1999	Lead	2.70	0	15	ppb	Corrosion of household plumbing systems; erosion of natural deposits.
1999	Copper	0.081	0	1.3	ppm	Corrosion of household plumbing systems; erosion of natural deposits.

2003 Total Coliform NOT DETECTED

Fecal Coliform NOT DETECTED

National Primary Drinking Water Regulation Compliance

This report was prepared by the Guadalupe-Blanco River Authority. Please contact GBRA at 361/552-9751 or through their website at www.gbra.org if more information is needed. Water quality data for community water systems throughout the United States is available at www.waterdata.com.